



Kiwa Fire Safety Compliance
Ground Floor, Suite A, Building 2
Bear Brook Office Park
Walton Street
Aylesbury, Buckinghamshire
HP21 7GQ

+44 (0)1844 275500
uk.firesafety@kiwa.com
www.kiwa.co.uk

Ref: Eclipse UK Ltd / 04 October 2023 / 24530

Date: 04 October 2023

Eclipse UK Ltd
Richmond House
Grantham
NG32 2BP

Dear Sir/Madam,

Use of Recessed Pull Handles in Conjunction with PAR/10057/01

We would confirm that you have previously commissioned Kiwa Fire Safety Compliance to prepare a revision to your Field of Application Assessment Report (referenced PAR/10057/01) for FD20 and FD30 single and double leaf sliding doors installed into timber frames. The assessment considers the overall fire resistance of the door assemblies if tested in accordance with BS476: Part 22: 1987.

Within the current revision of the report (Revision E), the 'Eclipse Recessed Pull handle' is only approved for use on the CF160 leaf design. You have indicated that you would like this scope to be extended to include the use of the 'Eclipse Recessed Pull Handle' with the XL Joinery FD30 leaf construction (referenced within the current revision of the report).

Our initial overview of the proposals, and relevant evidence, indicates that a positive appraisal will be possible, subject to the limitations and conditions, all as agreed, which will be included in the next revision (Revision F) of the Assessment Report.

Whilst this letter does not constitute an assessment, it is issued to confirm our intent to provide an extension to the current scope of approval for the proposed assemblies. This letter should not, in isolation, be used to demonstrate compliance with Building Codes or Regulations, and is valid for 30 working days, or until the next revision of the assessment report (to be referenced PAR/10057/01 Revision F) is issued, whichever is the sooner.

The full details of the assemblies, as approved, will be described in the report, but, for clarification, the following represents a summary of this particular scope extension.

- The use of the 'Eclipse Recessed Pull Handle' will be extended for use with the FD30 XL Joinery door leaves, when constructed using the leaf build-up 'Option 1'.
- Door leaves with the following styles, constructed in accordance with 'Option 1', will be approved to be fitted with the proposed recessed pull handles, assuming they are installed into areas of these leaves that are unrehabilitated, and subject to the limitations defined within the Assessment Report.
 - Ravenna
 - Salerno
 - Forli
 - Palermo



Registered Address: Kiwa UK Group Kiwa House, Malvern View Business Park, Stells Way, Bishops Cleeve, Cheltenham. GL52 7DQ
Registered No: 2194010



We trust that this letter is of assistance at this time. Should you have any questions regarding its contents, please contact the undersigned.

Yours faithfully

A handwritten signature in black ink, appearing to be "RS", written over a light blue horizontal line.

Richard Smart
MEng (Hons) AIFireE ACABE
Fire Safety Engineer
Kiwa Fire Safety Compliance
(part of the Kiwa UK Group)

A handwritten signature in black ink, appearing to be "W Lightfoot", written over a light blue horizontal line.

William Lightfoot
BEng (Hons) MSc AIFireE ACABE
Senior Fire Safety Engineer
Kiwa Fire Safety Compliance
(part of the Kiwa UK Group)

